

### IOT0085 4-button panel SHE BT HYT white IoT

### 625367 4-button panel SHE BT HYT black IoT

#### **Product Description**

The 4-button panel is available in black and white. As a communication element, it uses the HBTD8200P/F controller. The HBTD8200P/F controller has 4 SELV Push inputs (low voltage). A control signal is sent via Bluetooth to control on/off, dimming, changing the color temperature of the luminaire, or to call up scenes. Simple configuration and commissioning of the panel can be done using the Lena Lighting Clue application.







#### App Features

Floorplan feature to simplify project planning

Grouping luminaires via mesh network

Scenes

Push switch confguration

Schedule to run scenes based on time and date

Astro timer (sunrise and sunset)

Device frmware update over-the-air (OTA)

Power-on status (memory against power loss)

Offline commissioning

P Different permission levels via authority management

Network sharing via QR code or keycode

Remote control via gateway support HBGW01

( Interoperability with Bluetooth product portfolio

Compatible with EnOcean BLE switches

Continuous development in progress...

### Hardware Features



Compact design



4 SELV Push switch inputs



5-year warranty

\* Certain scenes which require external photocell can be achieved by using together with Bluetooth sensors, such as HBIR29, HCD038/BT + sensor head etc.












Fully support EnOcean self-powered switch module PTM215B (HBES01/W & HBES01/B)



Edition: 29 May. 2024


## Technical specification of the panel


Physical	
Dimensions (HxWxD)	70x70x12 mm (without handle)
Material	Plastic
Colour	Black/White


Electric	
Maximum switching voltage	12 VDC / 18 VAC
Maximum switching current	50mA


Environment	
Ambient temperature	20° C to 70° C / -5° F to 158° F
Humidity	of the 85%


# Mechanical structure and panel dimensions











# **Technical Specifications Controller**


Bluetooth Transceiver	
Operation frequency	2.4 GHz -2.483 GHz
Transmission power	4 dBm
Range (Typical indoor)	10~30m
Protocol	Bluetooth 5.0 SIG Mesh


Input & Output Characteristics	
Operating voltage	220~240VAC 50/60Hz
Push switch voltage	14-16V
Stand-by power	<0.5W

Ta: -20°C ~ +50°C
Tc: +75°C
-40°C ~ +70°C
10 ~ 90%
IP20
Class II


Safety & EMC	
EMC standard (EMC)	EN55015, EN61547 EN61000-3-2/-3-3
Safety standard (LVD)	EN 61347-1,EN 61347-2-11, EN62493
RED	EN300328, EN301489-1 EN301489-17, EN50663
Certifcation	CE, UKCA, RCM

Subject to change without notice. Edition: 29 May. 2024 Ver. A0 Page 2/4






### Wiring Diagram



### Wire Preparation

To make or release the wire from the terminal, use a screwdriver to push down the button.





Wiring precautions:

1. A wire diameter of 0.5-4 mm for the AC input port

2.There is a standard wire diameter of 0.2-4mm for the PUSH port voltage (15V DC). Depending on the diameter of the wire, cable length can vary to optimize effectiveness. When connecting 0.2-0.5mm, the maximum length is 50m; when connecting 0.75-4mm, the maximum length is 100m.

Subject to change without notice.

# Dimming Interface Operation Notes

#### Switch-Dim

The provided Switch-Dim interface allows for a simple dimming method using commercially available non-latching (momentary) wall switches. Detailed Push switch configurations can be set on Lena Lighting Clue app.

Switch Function	Action	Descriptions
	Short press (<1 second)  * Short press has to be longer than 0.1s, or it will be invalid.	- Tum on/off - Recall a scene - Tum on only - Quit manual mode - Tum off only - Do nothing
Push switch	Double push	- Tum on only - Quit manual mode - Tum off only - Do nothing - Recall a scene
	Long press (≥1 second)	- Dimming - Colour tuning - Do nothing
Sensor-link (VFC signal only)	/	<ul> <li>Upgrade a normal on/off motion sensor to a Bluetooth controlled motion sensor</li> </ul>
Emergency Self-Test Function	Short press (<1 second)  * Short press has to be longer than 0.1s, or it will be invalid.	- Start Self test (Monthly) - Start Self test (Annually) - Stop Self test - Invalid
	Long press (≥1 second)	- Start Self test (Monthly) - Start Self test (Annually) - Stop Self test - Invalid
Fire Alarm (VFC signal only)	Refer to Lena Lighting Clue app	- Able to connect the Fire Alarm system -Once the fre alarm system is triggered, all the luminaries controlled by the Push Switch will enter the preset scene (normally it's full on), after the fre alarm system gives the ending signal, all the luminaries controlled by this Push Switch will revert back to normal status.

For more information, contact iot@lenalighting.pl  $\,$ 

Subject to change without notice. Edition: 29 May. 2024 Ver. A0 Page 4/4